



MUH JAIN GLOBAL SCHOOL

(1/7)

Ref. No. MUHJGS/GEN/01/24/241

Dated : 31/01/2024

The Executive Engineer/Assistant Engineer

Public Health Engineering Department

Tohana

Subject: - Regarding issue of certificate for safe drinking water and sanitary condition.

Sir,

It is to inform you that this institute vide its letter reference no. MUHJGS/98/05/23 dated 12-05-2023 has requested to issue the requisite certificate (copy enclosed). As per CBSE norms a certificate on appendix – XIII (format enclosed) was required to be issued from your good office. However same has not been issued so far. CBSE, Delhi which is a affiliating body is in the need of said certificate as per the format attached. You are again requested to do the needful on priority basis. It is urgently required by the institute.

Thanking you

Kind Regards

Principal
MUH Jain Global School
Kanheri (Tohana)

31-01-2024

D.A. as above.

Principal
MUH Jain Global School
Kanheri (Tohana)

Ajay Kumar Jaisi
President/Secretary
MUH Jain Global School
Kanheri (Tohana)

3KM STONE, VILLAGE KANHERI, TOHANA-HISAR ROAD, TOHANA-125120, DISTT. FATEHABAD (HARYANA)

Contact Details : 79885-70783, 98171-94629 Email : muhjainschool@gmail.com

Run by : Baldev Educational and Welfare Trust. (Regd No. 99 dt. 17-04-2017)

2/7

PUBLIC HEALTH ENGINEERING DEPARTMENT, HARYANA	
Payment Receipt Of Water Sample Test (Consumer Copy)	
Test ID : S28055	Date : 07-Feb-2024 12:25:07 PM
Received from : MUH JAIN GLOBAL SCHOOL	Lab Name : FATEHABAD Distt. Lab.
District : FATEHABAD	Chemist: KANCHAN BISHNOI
Block : TOHANA	Sample Location : 3KM STONE NEAR KANHERI
Village : KANHRI	Address : Main Water Works, Bhattu Road
By : Online Payment	
Online Transaction No. : Sfe7937a8abad2bf9af3	GRN No. : 112696965
Test Name: Physical & Chemical Test	
Test Parameter	
Total Dissolved Solids @ 180°C ± 2°C	
Total Hardness as CaCO ₃	
Calcium as Ca	
Magnesium as Mg	
Iron as Fe	
Chloride as Cl	
Sulphate as SO ₄	
Fluoride as F	
Nitrate as NO ₃	
pH @ 25°C	
Total Alkalinity	
Color	
Odour	
Taste	
Turbidity	
Free Residual Chlorine	
Rs. 250 (In words TWO HUNDRED AND FIFTY only)	

Principal
MUH Jain Global School
Kanheri (Tohana)

Ajay Kumar Jain
President/Secretary
MUH Jain Global School
Kanheri (Tohana)



3/4

OFFICE OF THE CHEMIST
WATER TESTING LABORATORY PUBLIC HEALTH
ENGINEERING DEPARTMENT, FATEHABAD



E-mail:-chemist.fatehabad@phedharyana.gov.in, chemistftbad7@gmail.com

Chemical Examination Report of Water Sample

Test Report No :- FTBD/03903/2/2024	Issue Date :- 07-02-2024
Issue To:- MUH JAIN GLOBAL SCHOOL,3KM STONE NEAR KANHERI	Location:- W/s MUH JAIN GLOBAL SCHOOL
Your Reference No - By Hand Date 07-02-2024	Collected By :- Sender himself
Sample Type - Drinking Water	Sample Received Date & Time :- 07-02-2024
Lab Job Order No.- PC - 1971443	Sample Received Date & Time :- 07-02-2024
Date(s) of Analysis :- 07-02-2024 to 07-02-2024	Sample Quantity :- 1 Ltr

Eviornmental Conddion :- Temp. 25± 2 °C Humidity 55 ± 15 %

Results

S. No.	Parameter	Protocol Used	Results	IS: 10500:2012 (Second Revision) RA- 2018		Unit
				Desirable limit	Max. Permissible limit (in absence better alternate source)	
12	Iron	APHA 3500-Fe B,2017 23rd Edition 2017	0.01	1.0	1.0	mg/L
13	Sulphate	APHA 4500 E 23rd Edition 2017	32	200	400	mg/L
14	Fluoride (as F)	APHA 4500 -F D,C2017 23rd Edition 2017	0.31	1.0	1.5	mg/L
15	Nitrate (as NO ₃)	APHA 4500-NO ₃ -D:2017 23rd Edition 2017	9	45	No relaxation	mg/L

Remarks:-The Parameter Tested at Sr.No 7-11 as per requirement of IS:10500:2012 second Revision (RA2018).
Note

s:

- The results given above are related to the sample as received and tested in PHED Lab, Fatehabad Reliability of sample lies with the sender.
- The test report can't be regenerated/re-produced in whole or in part without written permission of Laboratory.
- The test report can't be used for any publicity or any legal purpose.
- The test samples meant for chemical analysis will be disposed off after 15 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Sample analyzed by

(Kanchan Bishnoi)

Authorized Signatory/Chemist
PHED Water Testing Laboratory,Fatehabad

Principal
MUH Jain Global School
Kanheri (Tohana)

Ajay Kumar Jain
President/Secretary
MUH Jain Global School
Kanheri (Tohana)



**OFFICE OF THE CHEMIST
WATER TESTING LABORATORY PUBLIC HEALTH
ENGINEERING DEPARTMENT, FATEHABAD**

E-mail:-chemist.fatehabad@phedharyana.gov.in,



Chemical Examination Report of Water Sample

Test Report No :- FTED/03903/2/2024			Issue Date :- 07-02-2024		TC-12220	
Issue To:- MUH JAIN GLOBAL SCHOOL,3KM STONE NEAR KANHERI			Location:- W/s MUH JAIN GLOBAL SCHOOL			
Your Reference No - By Hand Date 07-02-2024			Collected By :- Sender himself			
Sample Type - Drinking Water			Sample Received Date & Time :- 07-02-2024			
Lab Job Order No.- PC - 1971443			Sample Received Date & Time :- 07-02-2024			
Date(s) of Analysis :- 07-02-2024 to 07-02-2024			Sample Quantity :- 1 Ltr			
Eviornental Condition :- Temp. 25± 2 °C Humidity 55 ± 15 %						
Results						
S. No.	Parameter	Protocol Used	Results	IS: 10500:2012 (Second Revision) RA- 2018		Unit
				Desirable limit	Max. Permissible limit (in absence better alternate source)	
1	Total Dissolved Solids @ 180°c ± 2°c	APHA 24th Edition - 2540 C	68	600	2000	mg/L
2	Total Hardness (as CaCo3)	APHA 24th Edition-2340-Hardness Method C (EDTA Method):	100	200	600	mg/L
3	Calcium (as Ca)	APHA 24th Edition 3500-C	16.032	75	200	mg/L
4	Magnesium (as Mg)	APHA 24th Edition 3500-Mg Method B (Calculation)	14.5	30	100	mg/L
5	Total Alkalinity (as CaCo3)	APHA 24th Edition-2320-Method B (Titration)	70	200	600	mg/L
6	Chloride (as Cl)	APHA 24th Edition 4500-Cl Method B(Argentometric Method) 2017	159.9	250	1000	mg/L
7	pH @ 25°c	APHA 24th Edition 4500-II+Method B	7.31	6.5 -8.5	No relaxation	-
8	Turbidity	APHA 24th Edition - 2130	0.91	1	5	NTU
9	Taste	IS 3025 (PART-7)	Agreeable	Agreeable	Agreeable	-
10	Odour	IS 3025 (PART-5)	Agreeable	Agreeable	Agreeable	-
11	Color	APHA 24th Edition 2120 B	<5	5 Hazen	15 Hazan Units	Hazen Units

Remarks:-The Parameter Tested at Sr.No 1-11 is per requirement of IS:10500:2012 second Revision (RA2013).

Notes:

- The results given above are related to the sample as received and tested in PHED Lab, Fatehabad Reliability of sample lies with the sender.
- The test report can't be regenerated/re-produced in whole or in part without written permission of Laboratory.
- The test report can't be used for any publicity or any legal purpose.
- The test samples meant for chemical analysis will be disposed off after 15 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Sample analyzed by

(Signature)
Principal
MUH Jain Global School
Kanheri (Tohana)

(Signature)
Ajay Kumar Jain
President/Secretary
MUH Jain Global School
Kanheri (Tohana)

(Signature)
(Kanchan Bishnoi)
Authorized Signatory/Chemist
PHED Water Testing Laboratory, Fatehabad



कार्यालय उपमंडल अभियंता, जन-स्वास्थ्य अभियांत्रिकी उपमंडल नं. 1, टोहाना।
O/O The Sub Divisional Engineer, Public Health Engg. Sub Division No.1, Tohana
E-Mail ID :- sdo.officetohana@gmail.com

5/7



To

The Principal
MUH Jain Global School,
Village Kanheri Hisar road Tohana.

Memo No. : 624

Date : 12.02.2024.

Sub :- Regarding issue of certificate for safe drinking water & Sanitary Condition.

Ref :- Vide Executive Engineer, PHED Tohana Endst. No. 2327 dated 31.01.2024

As per above cited subject the water sample sent by Prop. of MUH Jain Global School, Village Kanheri Hisar road Tohana for chemical analysis test to Water Testing Laboratory, Public Health Engineering Department, Fatehabad from private source exist in school campus and as per report of above said Lab vide Job Order No.PC-1971443 dated 07.02.2024 drinking water sample found Chemically potable. And certificate regarding maintaining the Hygienic Sanitation condition in school building of rural area belong's to Development & Panchayati Raj Department.

DA/- A copy of Test Report.


Sub Divisional Engineer

Endst. No. :

Date : 12.02.2024.

A copy of the above is forwarded to The Executive Engineer, PHED, Tohana w.r.t. 2327 dated 31.01.2024 for information and necessary action please.


Sub Divisional Engineer


Principal
MUH Jain Global School
Kanheri (Tohana)


President/Secretary
MUH Jain Global School
Kanheri (Tohana)



Ref. No. MUHJGS/GEN/02/24/144

Dated: 22/02/2024

*Sh. Baldev Singh
Site visit report
22/2/2024*

To
The SDO/AE
Panchayati Raj Department
Tohana (Fatehabad)

Subject:- Request for issuing certificate for the safe drinking water and sanitary condition, regarding.

R/Sir,
It is to inform you that as per CBSE norms this institution is in the need of above titled certificate on the enclosed Performa(Annexure XIII).The test report regarding potable water is also enclosed here with. You are therefor requested to issue the same on the enclosed Performa.

Thanking You

Kind Regards

[Signature]
President/Secretary
MUH Jain Global School
Kanheri (Tohana)

*भारत - अन्नदाता आदिवासी पशुपाल
शुद्ध पेयजल की सुरक्षा
Water & Sanitary Condition
का निरीक्षण किया गया।
सर्व कार्य सुचारु रूप से चल रहा है।
सभी रिपोर्ट आदिवासी मंडल
के अधिकारी पर्यवेक्षण के अधीन हैं।*

[Signature]

[Signature]
Principal
MUH Jain Global School
Kanheri (Tohana)

[Signature]
President/Secretary
MUH Jain Global School
Kanheri (Tohana)

[Signature]
SBO (PA)
Tohana
22/2/2024

[Signature]
President/Secretary
MUH Jain Global School
Kanheri (Tohana)

7/7

APPENDIX-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 369

Date: 1/03/2024

It is certified that an inspection team headed by Dalbir Singh, SDO (PR)
(Name of Officers with designation) from Dalbir Singh, SDO (PR)
(Name of Department/Office) inspected the **MUH Jain Global School, Village Kanheri, Hisar road
Tohana** on 18/2/2024 (date of inspection) and found that the **MUH Jain Global School** has safe
drinking water facilities for the students and members of staff of the institution and is maintaining the
hygienic sanitation condition in the school building & the campus as per the norms prescribed by the
Central/State/U.T Govt.

The above valid for a period of one Year

Signature with Seal: M. S. SDO (PR)
Name: Dalbir Singh
Designation: SDO (PR)
Name & Address of the Office/
Department DO SDO (PR), Tohana

To
President, MUH Jain Global School,
Village Kanheri, Hisar road Tohana.

Dev. and Panchayat Pimp

Ajay Kumar
Principal
MUH Jain Global School
Kanheri (Tohana)

Ajay Kumar Jain
President/Secretary
MUH Jain Global School
Kanheri (Tohana)